Thermalito
Union Elementary
School District

BOARD ACTION ITEM SUMMARY

TO:	Board of Trustees
FROM:	Joyce Dennison

MEETING DATE**:**	**August 24, 2017**
TOPIC:	Approval to contract with Efficient Energy Concepts, Inc., to replace one HVAC unit at Sierra Ave office.
DESCRIPTION:	It has come to our attention that the HVAC unit at Sierra Avenue School needs to be replaced. Due to the age of the unit at Sierra Ave office, we are recommending replacement for a total cost of $7,345.00.
FUNDING:	Restricted Maintenance

Efficient Energy Concepts, Inc.
7 Three Sevens Lane Chico,Ca 95973
Phone(530)879-3030 Fax(530-879-3034
CSL#694655

Billing Information | **Job Information**

Name: Thermalito School District	*Check here if same as Billing*	**PO**	
Address: 400 Grand ave	***name: Sierra Main office***	cap flashing	
City: Oroville, CA 95966	***Address:***	Change out	x
PH: 538-8825	***City:***	Cut-in	
Fax: 538-2969	***Phone:***	New. Const.	

Included	**Proposed Work**	**Excluded**
Replacement of 3 Ton package unit on roof of main office		**Fees & Permits**
Removal and disposal of old equipment		
Roof curb adaptor and sheet metal adaptor		
Crane lift		
Electrical and gas conversions		
All Labor to complete		
(Day and Night 14 seer)		
(5 year warranty)		
Billing to be 100% upon completion	**Base Total**	**$7,345.00**

Alternet pricing

Allow 2 weeks for delivery

Note:

Technician signature	**Customer signature**	**Date**
derrick deatherage		**8/9/2017**

Comments:

Thank you if you have any ?'s call Derrick 530-624-7368

Perform Work Yes No